

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lišem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 1240430

Product: Switchgear for electrometers

Type: EJ1R, 2EJ1R,
E1R, 2E1R, 3E1R, 4E1R,
E2R, 2E2R, 3E2R, 4E2R

Rating: 3x 230/400 V, 50 Hz, to 63 A, IP44/20C

Ordering firm: SFOS SK s.r.o.
Školská 1901, 979 01 Rimavská Sobota, Slovakia

Manufacturer: SFOS.SK s.r.o.
Školská 1901, 979 01 Rimavská Sobota, Slovakia

Trade mark:

The test results are stated in the test-report No.: 242022-01/01 of: 29.08.2024

A sample of the product was found to be in conformity with:
ČSN EN 61439-3:12 cl. 6, 10.2.6, 10.2.7, 10.3, 10.4, 10.9.2, 10.9.4, 10.10.4, 10.11.2, 10.12 (J.9.4.3.1, J.9.4.4.1), 10.13

Other data:

The validity of the certificate is limited to: 02.09.2027

03.09.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



242022-01